

GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From:
S.Sreedhar Reddy, M.A
District Fire Officer
Medak at Patancheru

To: ✓
The Correspondent,
A.P.College of Elementary Education
(B.Ed & D.Ed), Duddeda, Medak District.

Rc.No.2705/A1/2014, Dated: 23-12-2014.

Sir,

Sub:- **Telangana State Disaster Response & Fire Services Department - Central Region - Medak District-** Issuance of No Objection Certificate for Occupancy to the Existing Educational Building of A.P.College of Elementary Education (B.Ed & D.Ed), Sy.No.609, Duddeda (V), Kondapak (M), Medak District-Reg.

- Ref:-**
1. Section 13 (2) of A.P. Fire Services Act, 1999 and Rule 15(2) of A.P. Fire and Emergency Operations and Levy of Fee Rules, 2006.
 2. Chief Office instructions Memo.Rc.No.2305/B2/2007, dt.28-02-2007 and 12-09-2008.
 3. Letter of the Correspondent, A.P.College of Elementary Education, Duddeda, Medak District.
 4. Inspection report Rc.No.2705/ADFO & SFO/SDPT/2014, Dt.22-12-2014 of the Assistant District Fire Officer, Medak and Station Fire Officer, Siddipet.

\$ \$ \$ \$ \$

Vide reference 3rd cited, the Correspondent, A.P.College of Elementary of Education has reported that he has constructed Educational Building without obtaining Provisional No Objection Certificate from this Department and requested to issue the No Objection Certificate for Occupancy to the Existing Educational building of A.P. College of Elementary Education (B.Ed & D.Ed), Sy.No.609, Duddeda (V), Kondapak (M), Medak District.

2. Vide reference 4th cited, the Assistant District Fire Officer, Medak District and the Station Fire Officer, Siddipet inspected the building on 22-12-2014 and recommended for the issue of No Objection Certificate for Occupancy to the above Educational Building.

3. Particulars of the Educational Building:-

- i) Height of the Building: **8.20 Meters.**
- ii) Open spaces:

Direction	Required as per NBC-2005	Provided	Deficit/Remarks
North	N.A	N.A	N.A
East	N.A	N.A	N.A
South	N.A	N.A	N.A
West	N.A	N.A	N.A

iii). Floor wise particulars:

Sl. No	Floor	Floor Area in Sq. Meters	Occupancy	No. of students & Staff members in the floor
1	Ground floor	1102.00 Sq.Mtrs	Educational	100
2	First floor	465.60 Sq.Mtrs	Educational	80
	Total	1567.60 Sq.Mtrs	--	180

The Management has remitted Rs.19,500=00 (Rupees Nineteen thousand five hundred only) vide Challan No.0000030546, Dt.20-12-2014 at SBH., Siddipet Br towards the fire precaution fee and penal amount.

(PTO)

iv) (a) Means of Escape :

Sl.No.	Details of Staircase	Provided	
		Nos	Width in Meters
1	Internal Staircases.	1 No.	1.60 Mtrs
2	External Staircases	--	--
	Total	1 No.	1.60 Mtrs

Note: The Management is advised to provide another staircase with a width of 01.50 Mtrs with in three (03) months of issue of this Certificate.

(b) Details of Occupant Load per unit Exit Width in each floor:

Sl No	Floor	Built up Area in Sq Mtrs	No. of Occupants	Means of Escape as per NBC-2005	Provided
1	Ground	1102.00 Sq.Mtrs	100	--	--
2	First floor	465.60 Sq.Mtrs	80	1.60 Mtrs	1.60 Mtrs

V) (1) Fire Safety Measures:

Sl. No	Fire safety Measures	Required as per Table 23 of NBC of India 2005	Provided	Deficiency
1	Fire Extinguishers	14 No.s	14 No.s	Nil
2	Hose Reel	N.A	N.A	N.A

(2) Floor wise fire fighting Installations provided by the management:

Sl.No	Floor	Extinguishers	Hose Reel	Automatic Sprinkler System	Terrace Tank	Fire Pumps
1	Ground	10 No s	NA	NA	NA	NA
2	First Floor	04No's	NA	NA	NA	NA
	Total	14 No's	-	-	-	-


4. The Existing Educational Building of A.P. College of Elementary Education (B.Ed & D.Ed), Sy.No.609, Duddeda (V), Kondapak (M), Medak District.has provided with Fire Safety measures prescribed in Part 4, NBC - 05.

5. Therefore, the No Objection for Occupancy is issued to the Existing Educational building of A.P. College of Elementary Education (B.Ed & D.Ed), Sy.No.609, Duddeda (V), Kondapak (M), Medak District, subject to the condition of provision of another stair case within three (03) months from the date of issue of this Certificate and following conditions.

i.	All the fire protection arrangements shall be maintained in good condition as seen during inspection.
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached.
iii.	All the occupants must know the correct method of operation of the fire fighting system installed.
iv	Any loss of life or property due non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v	All Students / Staff members of the institutions shall be trained to operate the fire safety equipments during emergency.
vi	Addition / alteration, if any in the building may be obtained with prior permission from this Department.
vii	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 Months.

6. **This Occupancy Clearance is valid for a period of One year only ie., 22-12-2015 only. The Management is requested to submit application for renewal of No Objection Certificate for Occupancy before one month of expiry of the Certificate.**

Yours faithfully,


23/1/14
District Fire Officer,
Medak District.